

NO. 12 (version 2)

1. Unique product type identification code

UT1EF

2. Intended use of the construction product

Data transmissions in buildings and other engineering structures to reduce the occurrence and spread of fire and smoke.

3. Producer

Reichle & De-Massari Czech Republic a.s.

Vítězství 67

405 02 Děčín 33 – Nebočady

+420 412 548 438-9

vaclav.spacek@rdm.com

4. System of assessment and verification of constancy of performance of construction products

AVCP 3

The notified testing laboratory 1014 carried out a screening test of samples taken before placing on the market.

5. Harmonized standard

Base characteristics	Properties	Harmonized technical standard
Reaction to fire	Dca-s2,d1,a1	EN 50575:2014/A1:2016
Dangerous substances	no release	EN 50575:2014/A1:2016
Flammability in bundles	Extent of damage < 1.5 m	EN 60332-3-22 (cat.A)
Smoke density	Light transmission > 80%	EN 61034-1, EN 61034-2
Halogen Free, Acid gases	Conductivity < 1,8 µS/cm, PH > 5,8	EN 60754-2

6. Declared performances

The characteristics of the product referred in point 1 are in accordance with the properties declared in point 5. This declaration of performance is issued under the sole responsibility of the manufacturer referred to in point 3. Signed on behalf of the manufacturer

Signed for and on behalf of the manufacturer by Václav Špaček,
Head of Testing Laboratory FOC in Děčín, 01.08.2018

