

## DoP No. 050

### 1. Unique product type identification code

UT9x1,7EFCF

### 2. Intended use of the construction product

Data transmissions in buildings and other engineering structures to reduce the occurrence and spread of fire and smoke.

### 3. Producer

Reichle & De-Massari Czech Republic a.s.

Vítězství 67

405 02 Děčín 33 - Nebočady

+420 412 548 438-9

cze@rdm.com

### 4. System of assessment and verification of constancy of performance of construction products

AVCP 3

The notified testing laboratory 1014 carried out a screening test of samples taken before placing on the market.

### 5. Declared performances

Base characteristics	Properties	Harmonized technical standard
Reaction to fire	Eca	EN 50575:2014+A1:2016
Dangerous substances	no release	EN 50575:2014+A1:2016
Flammability in bundles	Extent of damage < 1.5 m	EN 60332-3-22 (cat.A)
Smoke density	Light transmission > 80%	EN 61034-1, EN 61034-2
Halogen Free, Acid gases	Conductivity < 1,8 $\mu$ S/cm, PH > 5,8	EN 60754-2

The performance of the product referred in point 1 are in accordance with the properties declared in point 5.

This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer referred to in point 3.

The document is valid from the date of issue until the release of a new version of the document.

Signed on behalf of the manufacturer by Ing. Václav Špaček,

Head of Testing Laboratory FOC in Děčín, 25.05.2020

